

ORIGIN OF WATER

Your drinking water originates from groundwater wells located in the Lake Michigan and Kankakee Basin Aquifers. Water is no longer drawn from Flint Lake. This water is treated to remove iron, and manganese and then filtered and disinfected.

Some compounds that may be found in untreated water include: biological contaminants, such as viruses and bacteria; inorganic compounds, such as salts and metals; and organic compounds, such as pesticides and herbicides.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general public. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other micro bacterial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791


OUR COMMITMENT TO YOU

The Valparaiso Lakes Area Conservancy District and its water/sewer company LAC Utilities have been serving the Flint Lake Area for 48 years. The seven-member Board of Directors is dedicated to providing quality water and sewer services while enhancing the environment through improving drainage, preventing the loss of topsoil from injurious water erosion and flood preventions, control and monitoring. The board meets every third Wednesday at 5:30pm at the VLACD office, 1805 Burlington Beach Road, Valparaiso, IN 46383. The meetings are open to the public, comments and questions are welcome! To be on the agenda, contact our office 48 hours in advance of a meeting.



LAC UTILITIES ANNUAL WATER QUALITY REPORT 2025

PWSID # IN5264033



1805 Burlington Beach Road
Valparaiso, Indiana 46383
Monday-Friday 8:30-4:30
Phone: (219) 464-3770
Emergency: (219) 916-4638
vlacd.org

VALPARAISO CITY UTILITIES 2024									
SUBSTANCES TESTED AT THE TREATMENT PLANTS AND IN THE DISTRIBUTION SYSTEM									
SUBSTANCE	YEAR SAMPLED	UNITS OF MEASURE	MCL	MCLG	HIGHEST LEVEL DETECTED	AMOUNT RANGE	MCL VIOLATION	POTENTIAL HEALTH EFFECT	TYPICAL SOURCE
Barium	2024	ppm	2	2	0.057	0.046-0.057	NO	Increase in blood pressure	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chlorine	2024	ppm	MRDL=4.0	MRDLG=4	1	0.2-1.39	NO	Eye/Nose irritation, stomach discomfort	Water additive used to control microbes
Fluoride	2024	ppm	4	4	0.75	0.7-0.75	NO	Bone disease, children may get mottled teeth	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Nickel	2024	MG/L	0.1	0.1	0.0011	0-0.0011	NO	Long term exposure can cause heart and liver damage	Smelting & refining and steel works industries
Chromium	2024	ppb	100	100	3.3	2.6-3.3	NO	May cause allergic dermatitis if using water with chromium in excess of MCL over many years	Discharge from steel and pulp mills; erosion of natural deposits
Total Trihalomethanes	2023-2024	ppb	80	0	25	11.62-31.55	NO	Liver, kidney, or central nervous system problems; increased risk of cancer	Byproduct of drinking water chlorination
Total Haloacetic Acids	2023-2024	ppb	60	0	9	3.9-8.4	NO	Increased risk of cancer	By-product of drinking water disinfection
Coliform (TCR)	2024	Treatment Technique Trigger		0	Result: In the month of July, 1.54% of samples returned as positive			Naturally present in the environment	
SUBSTANCE TESTED FOR AT CUSTOMER'S TAP									
SUBSTANCE	YEAR SAMPLED	UNITS OF MEASURE	SITES OVER AL	ACTION LEVEL(AL)	90 TH PERCENTILE	AMOUNT RANGE	AL VIOLATION	POTENTIAL HEALTH EFFECT	TYPICAL SOURCE
Copper	2020-2023	ppm	0	1.3	0.54	0.0098-0.79	NO	Gastrointestinal distress	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	2020-2023	ppb	0	15	5.6	0.53-14	NO	Children: Delays in physical or mental development. Adults: Kidney problems	Corrosion of household plumbing systems; Erosion of natural deposits

LAC UTILITIES 2024								
DISINFECTANT	DATE	HIGHEST RAA	UNIT	RANGE	MRDL	MRDLG	VIOLATION	TYPICAL SOURCE
Chlorine	2024	1	ppm	0.9-1.1	4	4	NO	Water additive used to control microbes
DISINFECTION BYPRODUCTS	DATE	HIGHEST LRAA	UNIT	RANGE	MCL	MCLG	VIOLATION	TYPICAL SOURCE
Total Haloacetic Acids (HAA5)	2023-2024	1.7	ppb	1.66-1.66	60	0	NO	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM)	2023-2024	15	ppb	15-15	80	0	NO	Byproduct of drinking water chlorination
LEAD & COPPER	DATE	90 th PERCENTILE	UNIT	RANGE	AL	SITES OVER AL	VIOLATION	TYPICAL SOURCE
Copper	2021-2024	0.439	ppm	0.019-0.479	1.3	0	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead	2021-2024	0	ppb	1.27	15	0	NO	Corrosion of household plumbing systems; Erosion of natural deposits

Our system collected samples under the U.S. EPA Unregulated Contaminants Monitoring Rule (UCMR) for 29 PFAS compounds and Lithium. This monitoring is being conducted so the EPA can receive occurrence data for these compounds to determine what additional compounds may need to be regulated in drinking water. We collected samples in September and did not detect any of the compounds. If you would like to view our results, contact our office at 219-464-3770.

For more information about this report, please contact
Alicia Barber - General Manager
219-464-3770
a.barber@vlacd.org

Table Definitions

Action Level (AL): The concentration of contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Amount Range: This column represents a range of individual sample results, from lowest to highest, that were collected during the reporting year.

Locational Running Annual Average (LRAA): Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectants Level (MRDL): The highest level of a disinfectant allowed in drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health.

NA - Not Applicable.

picoCurie per Liter (pCi/L): A measure of radioactivity.

Parts per Billion (ppb): One part per billion (or micrograms per liter).

Parts per Million (ppm): One part per million (or milligrams per liter).

Running Annual Average (RAA): An average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

Special Health Information

Thanks to the Safe Drinking Water Act, the United States arguably has the safest water supply and distribution system in the world. However, if you have special health requirements, you should know some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

Substances Found in Drinking Water

To ensure that tap water is safe to drink, the EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Public water systems and water bottles use a variety of water sources. These sources include rivers, lakes, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it can acquire naturally occurring minerals, radioactive material (if present), and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

- Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants*, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticide and herbicide contaminants*, which may come from sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are byproducts of industrial, processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants* can naturally occur or be the result of oil and mining activities.

Special Information on Lead

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney, or nervous system problems. Contact your health care provider for more information about your risks.

You can access the lead service line inventory by visiting https://pws-pid.120wateraudit.com/1_A_C_Uilities_IN